



**Hays CISD**  
21003 IH 35  
Kyle, Texas 78640  
512-268-2141 ext. 45092  
Email: valerie.littrell@hayscisd.net

### **ADDENDUM 3**

**Date:** December 1, 2022

**RFP#:** 06-112201VL Access Control System Replacements

**Opening Date:** December 09, 2022 @ 2:00 p.m.

#### **NOTICE TO ALL BIDDERS:**

This addendum forms a part of the Contract Documents and modifies the original Bidding Documents. Where provisions of the following Addendum differ from the original specifications, the Addendum 3 shall govern and take precedence. Acknowledge receipt of this addendum in THE PROPOSAL FORM. Failure to do so may subject the bidder to disqualification.

#### **Clarifications:**

1. The following updates have been made to Section 11 Specifications and new Revised ACS RFP Panel Info; Revised ACS RFP Parts List and Revised ACS RFP Price Sheet

REVISED Section 11 – Specifications to Chapa Middle School:

#### **Chapa Middle School**

- **MDF E104** – Remove existing DSX controllers and install the following Mercury controllers:
  1. (1) LP1502 intelligent controller
  2. (2) MR52-S3 sub-controllers
  3. (1) OptoHub multiplexer
- **IDF C108** – Remove existing DSX controllers and install the following Mercury controllers:
  1. (4) MR52-S3 sub-controllers
- **IDF A135** – Remove existing DSX controller and install the following Mercury controller:
  1. (1) MR52-S3 sub-controller
- Establish RS-485 communication links using the OptoHub multiplexer from panel in MDF E104 to panels in IDF C108 and IDF A135.
- Program (16) doors into DNA Fusion.

Valerie Littrell  
Buyer

In the submission of the response, vendor must acknowledge receipt of this addendum. Otherwise this offer may not be given consideration. Vendor may acknowledge receipt on face of response or by returning one copy of this notice.

---

Signature of Bidder

---

Printed Name

---

Company Name